



**NOTES :**

1. Make threaded and bolted 3/4" diameter tierod connections to fitting with approved ductile lugs or 90° eye bolts.
2. Use 5-sack cement concrete. calcium additive not allowed.
3. Wrap fittings with 6-mil plastic sheet. concrete must not interfere with flange bolt removal.
4. Tierods are not allowed between the hydrant and its gate valve.
5. Restraining glands such as the "mega-lug" brand that impose point loading on the pipe are not allowed.

dwc 12-01  
dwc 3-00

P:\Engr & CAD\STANDARD DWGS - ALL YEARS\Std Dwgs 2014\Thrust Block - Saddle 15.dwg

ZGS

# SADDLE BLOCK

PAGE NO:

15